


Notes:

- 1 New water main size to be determined by Erie County DOES
- 2 Concrete thrust blocks should be installed at end caps
- 3 Concrete encase w/ Class C Concrete



A-A
TYPICAL DRAWING FOR
REROUTING W.M. @ CULVERT / DITCH